



# NET POSITIVE SUCTION HEAD

FRED LUSK, P.E.

## INTRODUCTION

Net Positive Suction Head (*NPSH*) is the measure of positive fluid pressure on the suction side of a pump. Unless the available *NPSH* ( $NPSH_a$ ) exceeds—with appropriate safety factors—the required *NPSH* ( $NPSH_r$ ), the pump will likely not operate properly, including increased vibration, not pumping, and/or cavitation. This worksheet calculates the *NPSH* conditions for a centrifugal pump.

## EQUATIONS

Net Positive Suction Head Available: [1]

$$NPSH_a = H_{atm} + H_{st} - H_{fr} - H_{vp} - H_{vol} - U$$

$$NPSH_a = [\text{Atmospheric Head}] + [\text{Static Head}] - [\text{Friction Head Losses}] - [\text{Vapor Pressure Head}] - [\text{Partial Pressure Head of Dissolved Gases}] - [\text{Uncertainty}]$$

Note: The inlet Velocity Head is included by the pump manufacturer in the  $NPSH_r$ , and thus is not included here. Friction Head Losses are suction-side losses only.

## DEFINITIONS

$$psia \equiv psi \quad pcf \equiv \frac{lbf}{ft^3} \quad mm\_Hg \equiv \frac{in\_Hg}{25.4}$$

## DATA — PROJECT

Pump:	Mfr / Model / Impeller	
Design pumping range:	$Q_{min} := 800 \text{ gpm}$	$Q_{max} := 1000 \text{ gpm}$
Maximum $NPSH_r$ over range of $Q$ :	$NPSH_r := 25.0 \text{ ft}$	(per pump manufacturer)
Elevation (above MSL):	$Elev := 350 \text{ ft}$	
Maximum water temperature (°F):*	$T_F := 65$	$T_C := \frac{5}{9} \cdot (T_F - 32) = 18.3$
Minimum Static Head on pump suction:	$H_{st} := 10.00 \text{ ft}$	(negative if lift to pump)
Friction Head Losses in suction piping:	$H_{fr} := 7.50 \text{ ft}$	(pipe losses + minor losses)
Partial Pressure Head of Dissolved Gases:	$H_{vol} := 0.00 \cdot \text{ft}$	
Uncertainty:	$U := 3.00 \text{ ft}$	

Note: Do not use units here. Unlike MC 15, MC Prime cannot strip temperature units as required below.

Note: Typically use zero for water and about 2 ft for wastewater.

Note:  $U$  is an additional factor of safety to account for uncertainty in the data, the hydraulic calculations, etc.

**DATA – OTHER**

NPSH Safety Factors for comparing  $NPSH_a$  &  $NPSH_r$ : [2]

Difference:  $SF_1 := 5 \text{ ft}$

Ratio:  $SF_2 := 1.35$

Weight density of water:  $\gamma_w := 62.4 \text{ pcf}$

U.S. Standard Atmosphere (1976):  $Altitude$   $P_{static}$  [3]

$(m)$	$(Pa)$
0	101325
11000	22632.1

**CALCULATIONS**

Atmospheric Pressure & Head:

Atmospheric Pressure:  $P_{atm} := \text{linterp}(Altitude, P_{static}, Elev)$

$P_{atm} = 14.59 \text{ psi}$

Atmospheric Head:

$H_{atm} := \frac{P_{atm}}{\gamma_w} = 33.66 \text{ ft}$

Vapor Pressure & Head

Vapor Pressure (Antoine Equation)  $P_{vp} := 10^{\left(8.07131 - \frac{1730.63}{233.426 + T_C}\right)} \text{ mm}_H\text{g}$  [4]

$P_{vp} = 0.30 \text{ psi}$

Vapor Pressure Head:

$H_{vp} := \frac{P_{vp}}{\gamma_w} = 0.70 \text{ ft}$

Net Positive Suction Head Available:

$NPSH_a := H_{atm} + H_{st} - H_{fr} - H_{vp} - H_{vol} - U$

$NPSH_a = 32.46 \text{ ft}$

$NPSH_a - NPSH_r = 7.46 \text{ ft}$

$\frac{NPSH_a}{NPSH_r} = 1.30$



## **CHECK RESULTS**

```
Result:= || if  $NPSH_a - NPSH_r \geq SF_1$  ||  
          || ||  $\frac{NPSH_a}{NPSH_r} \geq SF_2$  ||  
          || ||  $Pump \leftarrow \text{"OK"}$  ||  
          || else ||  
          || ||  $Pump \leftarrow \text{"NO GOOD"}$  ||  
          || else ||  
          ||  $Pump \leftarrow \text{"NO GOOD"}$  ||
```

The  $NPSH_a$  for this pump is:  
Result = "NO GOOD"

## **REFERENCES**

- [1] Sanks, Robert L., Editor-in-Chief, *Pumping Station Design, Second Edition*, Butterworth-Heinemann, Boston, 1998, p. 258, Eq. 10-23.
- [2] Ibid, p. 259.
- [3] [http://en.wikipedia.org/wiki/U.S.\\_Standard\\_Atmosphere](http://en.wikipedia.org/wiki/U.S._Standard_Atmosphere), November 20, 2013.
- [4] [http://en.wikipedia.org/wiki/Antoine\\_equation](http://en.wikipedia.org/wiki/Antoine_equation), November 20, 2013